

 TRELLEBORG	Quality Department Certification	Page	1 / 1
--	---	------	--------------

CERTIFICATE

Article Description

S1774080	MK 3.0X1400X10000 GY DIL
S1774090	MK 5.0X1400X10000 GY DIL

Trelleborg Izarra, S.A.U. hereby certifies that our article above mentioned with our reference 5485 complies with the requirements of the Standard IEC EN 60243-1:2013

Electric Strength test at Power-frequently:

The test has been performed according to Standard IEC 60243-1:2013, "Electrical Strength of insulating material - Part 1: Tests at power frequencies".

Test Reference carried out: 4P07189:

Property	Unit	Standard Value
Dielectric Strength	kV	30 at 3.0 mm
Dielectric Strength	kV	50 at 5.0 mm



Izarra, 15/10/24
on behalf of PA Elastomer Laminates
Quality Department
María Gutiérrez-Cortines